

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

R 50606530 0001

Berichtsnummer Report No.:

CN23M4K6 002

Genehmigungsinhaber License Holder:

RECOM & CO LTD

1 Avlonos Street Maria House,

4th floor, Office No.7

1075 Nicosia

Cyprus

Fertigungsstätte Manufacturing Site:

040-0001344616

Prüfzeichen Test Mark:


Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111276642

Geprüft nach Tested according to:

VDE-AR-E 2510-50:2017

2 PfG 2698/08.19

Geräteidentifikation
Product Identification
Produkt:

Lithium-ion battery

Product:

(Lithium ion Rechargeable Battery System)

Modell:

Modelle sind auf nächste(r) Seite(n) gelistet

Type:

Type designation(s) are listed on the next page(s)

Technische Daten:

Refer to the next page(s)

Technical Data:
Gültig ab:


2024-04-29

Valid from:
Zertifizierungsstelle:
Certification body:
Ausstellungsdatum:

2024-04-29

Date of issue:

Weichun Li



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

<http://www.tuv.com/safety> E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

www.tuv.com

TÜVRheinland®
Precisely Right.

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

R 50606530 0001

Berichtsnummer *Report No.:*

CN23M4K6 002

Produkt *Product:*

 Lithium-ion battery
 (Lithium ion Rechargeable Battery System)

Modell *Type:*
Bezeichnung *Designation:*

For

: 1) RCM-BS-32.5	2) RCM-BS-30.0
3) RCM-BS-27.5	4) RCM-BS-25.0
5) RCM-BS-22.5	6) RCM-BS-20.0
7) RCM-BS-17.5	8) RCM-BS-15.0
9) RCM-BS-12.5	10) RCM-BS-10.0
11) RCM-BS-7.5	12) RCM-BS-5.0

Module Qt'y (n)

: 1) 13	2) 12	3) 11	4) 10
5) 9	6) 8	7) 7	8) 6
9) 5	10) 4	11) 3	12) 2

Rated Voltage[V]

: 1) 665.6	2) 614.4
3) 563.2	4) 512.0
5) 460.8	6) 409.6
7) 358.4	8) 307.2
9) 256.0	10) 204.8
11) 153.6	12) 102.4

Rated Capacity [Ah]

: 50

Max. Charge and Discharge Current [A]: 45

Protective Class

: I

Ingress protection (IP)

: IP65

Pollution Degree

: PD 2 (Inside)

Altitude[m]

: Below 3000

Remark(s):

 The installation has to be carried out according to the attached
 installation instruction.

 Any additional requirements in countries where the product is
 going to be marketed have to be considered additionally.
